

## Results of the monitoring in response to the accidents of Fukushima Dai-ichi NPP

1. Monitoring time 2011/03/25

2. The results of monitoring

(1) Yamamoto town district

Monitoring equipment: monitoring car

(unit:  $\mu$  Sv/h)

Monitoring post		Monitoring time	Reading
Sendai city	Parking of the main branch of Tohoku Electric Power	09:26~09:36	0.18
Natori city	Around the Natori city hall	15:36~15:46	0.20
Iwanuma city	Iwanuma branch office of Tohoku Electric Power	15:08~15:18	0.20
Watari town	Watari fire station	14:31~14:41	0.36
Yamamoto town	Around Yamamoto town hall	10:48~11:58	0.30
		11:47~11:57	0.31
		12:47~12:57	0.30
		13:47~13:57	0.30

(2) Shiraishi city district

Monitoring equipment: survey meter

(unit:  $\mu$  Sv) /h

Monitoring post		Monitoring time	Reading
Ogawara town	Around Ogawara town hall	15:33~15:43	0.42
Shiraishi city	Shiraishi branch office of Tohoku Electric Power	10:24~10:34	0.39
		11:24~11:34	0.39
		12:24~12:34	0.39
		13:24~13:34	0.39

(3) Others

If the maximum reading(0.42  $\mu$  SV/h) would have been lasted for 10 days, the total figure is about 1/100 of the standard (10,000  $\mu$  Sv) that residents have to shelter indoors.

Based on Press Release from Miyagi prefecture