

Results of the monitoring in response to the accidents of Fukushima Dai-ichi NPP

1. Monitoring time 2011/04/10

2. The results of monitoring

(1) South-East district

Monitoring equipment: monitoring car

(unit: μ Sv/h)

| Monitoring post | | Monitoring time | Reading |
|-----------------|-----------------------------------------------------|-----------------|---------|
| Sendai city | Parking of the main branch of Tohoku Electric Power | 08:59 ~ 09:09 | 0.09 |
| Yamamoto town | Around Yamamoto town hall | 10:11 ~ 10:21 | 0.18 |
| Marumori town | Around Marumori town hall | 11:20 ~ 11:30 | 0.29 |
| Kakuda city | Around Kakuda city hall | 12:04 ~ 12:14 | 0.28 |
| Watari town | Around Watari fire station | 12:58 ~ 13:08 | 0.19 |

(2) South-West district

Monitoring equipment: survey meter

(unit: μ Sv/h)

| Monitoring post | | Monitoring time | Reading |
|--------------------|--------------------------------------------------|-----------------|---------|
| Shichikashuku town | Around Shichikashuku town hall | 10:23 ~ 10:33 | 0.22 |
| Shiraishi city | Shiraishi branch office of Tohoku Electric Power | 11:10 ~ 11:20 | 0.22 |
| Ogawara town | Around Ogawara town hall | 11:50 ~ 12:00 | 0.22 |
| Iwanuma city | Iwanuma branch office of Tohoku Electric Power | 13:38 ~ 13:48 | 0.14 |
| Natori city | Around Natori city hall | 14:08 ~ 14:18 | 0.15 |

(3) Sendai city

Monitoring equipment: transportable monitoring post

Monitoring point: Miyagi Prefectural government hall building [rooftop]

(Aoba-ku, Sendai)

(unit: μ Sv/h)

| Monitoring time | Mean value | Maximum value | Minimum value | (Reference) Past range 2009/4 ~ 2011/3 |
|-------------------------------------------|------------|---------------|---------------|----------------------------------------------------------------------------------------------|
| 2011/04/09 18:00 ~ 2011/04/10 17:00 | 0.082 | 0.086 | 0.078 | 0.0176 ~ 0.0513 (Miyagi Prefectural Institute of Public Health and Environment) |

(4) Others

If the maximum reading(0.29 μ SV/h) would have been lasted for 10 days, the total figure is about 1/140 of the standard (10,000 μ Sv) that residents have to shelter indoors.

Based on Press Release from Miyagi prefecture